



Grabber Construction Products, Inc.
5255 West 11000 North
Highland, Utah 84003

May 18, 2006

Attention: Kelly Jones

Dear Sir:

Re: Environmental Exposure and Accelerated Aging of GrabberGard IFC Firestopping Sealant

This letter is to advise you that Underwriters Laboratories (UL) has completed the testing of GrabberGard IFC firestopping sealant in accordance with the new requirements of ANSI/UL 1479, *Standard Fire Tests of Through-Penetration Firestops*, dated May 23, 2003.

Based on the UL conducted tests, GrabberGard IFC firestopping sealant has met the requirements for Environmental Exposure and Accelerated Aging for Intumescent Materials as specified in the ANSI/UL 1479 Standard. As result, UL will continue to classify the GarbberGard IFC firestopping sealant after the effective date of the ANSI/UL 1479 Standard, May 23, 2006.

If you have any questions, please feel free to contact me.

Yours truly,

John Wagner & Associates

A handwritten signature in black ink, appearing to be "Norm Johnston", written over the printed name.

Norm Johnston
Manager Fire Lab & Technical Services